

**Water Quality
OAC 3701-31-04 (D) (6)**

Parameter	Pools*	Spas
Free Chlorine (FC)	1 ppm minimum	2 ppm minimum
Working Range	1 ppm to 5 ppm	2 ppm to 6 ppm
Total Bromine (TB)	2 ppm minimum	4 ppm minimum
Working Range	2 ppm to 7 ppm	4 ppm to 10 ppm
Combined Chlorine (CC)	1 ppm maximum	1 ppm maximum
Ideal Level	0	0
pH	7.2 to 7.8	7.2 to 7.8
Ideal Level	7.5	7.5
Total Alkalinity (TA)	60 ppm minimum	60 ppm minimum
Ideal Level	80 ppm-100 ppm for high pH disinfectants 100 ppm-120 ppm for low pH disinfectants	80 ppm-100 pm for high pH disinfectants 100 ppm-120 ppm for low pH disinfectants
Cyanuric ACID (CYA)	70 ppm maximum	70 ppm maximum
Temperature	90 degrees F maximum	104 degrees F maximum
*includes special use pools		